This document, concerning commercial and industrial pumps is an action issued by the Department of Energy. Though it is not intended or expected, should any discrepancy occur between the document posted here and the document published in the Federal Register, the Federal Register publication controls. This document is being made available through the Internet solely as a means to facilitate the public's access to this document.

6450-01-P

DEPARTMENT OF ENERGY

10 CFR Parts 429 and 431

[Docket No. EERE-2011-BT-STD-0031]

RIN 1904-AC54

Energy Conservation Program: Energy Conservation Standards for Pumps; Correction

AGENCY: Office of Energy Efficiency and Renewable Energy, Department of Energy.

ACTION: Notice of proposed rulemaking (NOPR) and public meeting; correction.

SUMMARY: On April 2, 2015, the U.S. Department of Energy (DOE) published in the Federal Register a notice of proposed rulemaking (NOPR) and public meeting for Energy Conservation Program: Energy Conservation Standards for Pumps. This document corrects the terms in one of the equations.

FOR FURTHER INFORMATION CONTACT: John Cymbalsky, U.S. Department of Energy, Office of Energy Efficiency and Renewable Energy, Building Technologies Program, EE–5B, 1000 Independence Avenue SW., Washington, DC, 20585–0121. Telephone: (202) 287–1692. Email: pumps@ee.doe.gov.

DATES: [INSERT DATE OF PUBLICATION IN THE FEDERAL REGISTER].

Correction:

In the Federal Register published on April 2, 2015, in FR Doc. 2015-06947, make the following correction:

On page 17836: Equation 2 is corrected by removing "13.46" and adding in its place "17.80". The corrected equation reads as follows:

$$\eta_{pump,STD} = -0.85 * \ln(Q_{100\%})^2 - 0.38 * \ln(Ns) * \ln(Q_{100\%}) - 11.48 * \ln(Ns)^2 + 17.80 * \ln(Q_{100\%}) + 179.80 * \ln(Ns) - (C - 555.6)$$

Issued in Washington, DC, on April 20, 2015.

Kathleen B. Hogan
Deputy Assistant Secretary for Energy Efficiency
Energy Efficiency and Renewable Energy